

 Electrical Safety Authority	Regulatory Centre of Excellence	Ref No: OESC-01-2024	Rev. No.: 0
	Director's Order	Date: June 22, 2026	

IN THE MATTER OF:

THE ELECTRICITY ACT, 1998

S.O. 1998, c. 15, Schedule A (the "Act")

- and -

ONTARIO REGULATION 164/99

(Electrical Safety Code) made under the Act

Subject: Amendment to the Ontario Amendments to the, Canadian Electrical Code Part 1, C22.1:24 documents

Sent to: Ontario Provincial Code Committee, Electrical Contractor's Association of Ontario, Ontario Electrical League, Ministry of Public and Business Service Delivery, ESA Advisory Councils, and Posted on ESA's Web-Site

The Director, pursuant to subsection 113 (5) (a) of the Electricity Act, 1998 hereby provides notice that the Ontario Amendments to the Canadian Electrical Code Part 1, C22.1:24 Document published by the Electrical Safety Authority, effective May 1, 2025 and adopted by the Electrical Safety Code Regulation (Ontario Regulation 164/99) is further amended as follows:

1. Amend Subrule 2-010 1) by deleting item (e) and replace with:
e) any installations within the scope of Section 64 or bi-directional electrical vehicle supply equipment, with an output rating in excess of 12 kW.

The above amendments have been made in order to align ESA's regulatory framework with current industry trends, development, and the *Ontario Energy Board's (OEB) Distribution System Code (DSC.)* The Ontario Amendments to the Canadian Electrical Code Part 1, C22.1:24 document has been amended, by way of this Director's Order, to reflect this change.

This Order takes effect on July 6, 2026.

Nansy Hanna

Nansy Hanna

Senior Director, Engineering & Regulations
Electrical Safety Authority