

Administrative Action Summary

Date	March 14, 2025
Name	Tom Main
Licensure Status at Time of Incident	Unlicensed
Administrative Action	Administrative Penalty
Location	Norwood, ON
Regulation Description	 Concealed or rendered inaccessible an electrical installation before it conformed to the Ontario Electrical Safety Code and/or before the concealment or rendering of the electrical installation inaccessible was authorized by an Inspector, contrary to Rule 2-004(7) of the Ontario Electrical Safety Code. Tom Main was ordered to pay an administrative penalty of \$2,000. Prior to the commencement of work to be done on an electrical installation at a residential property in Norwood,
	failed to file with the Electrical Safety Authority a Notification of the Work, contrary to Rule 2-004(1)(a) of the Ontario Electrical Safety Code. Tom Main was ordered to pay an administrative penalty of \$1,000.
	 Permitted or employed someone to carry out electrical work, which is an activity referred to in the regulations under the Act as requiring an authorization, who was not authorized to do so, contrary to ss. 113.2(1) of the <i>Electricity Act</i>, 1998.
	Tom Main was ordered to pay an administrative penalty of \$1,000.



Administrative Action Summary

	4. Permitted or employed someone to carry out electrical work, which is an activity referred to in the regulations under the Act as requiring an authorization, who was not authorized to do so, contrary to ss. 113.2(1) of the <i>Electricity Act, 1998</i> . Tom Main was ordered to pay an administrative penalty of \$1,000.
Description of Contravention	Tom Main, ("Main") was not authorized to propose, permit, or employ to carry out electrical work. Between December 1, 2022 and January 22, 2024, Main permitted or employed individuals who were not authorized to carry out electrical work (i.e. unlicensed), specifically, when they installed an electrical service panel on a residential property in Norwood, Ontario. Performing electrical work while not authorized is an activity referred to in the regulations under the Act as requiring an authorization. While performing the electrical work, the unlicensed individuals concealed or rendered inaccessible the electrical installation before it conformed to the Ontario Electrical Safety Code and also failed to file with the ESA a Notification of Work prior to the commencement of the work.
Additional Information	