

Bulletin 2-7-40
Approval of electrical equipment
Rules 2-022 and 2-024

Issued May 2025
Supersedes Bulletin 2-7-39

Scope

- 1) Approval requirements
- 2) Approval of customer owned metering equipment
- 3) Approval of meter-mounted transfer switch devices

1) Approval requirements

The Ontario Electrical Safety Code (OESC) and Ontario Regulation 438/07 “Product Safety,” recognize Certification Bodies accredited by the Standards Council of Canada to approve electrical equipment to meet the requirements of the Code. Only equipment bearing one of the marks shown in the following link are deemed acceptable by the Electrical Safety Authority (ESA): <https://esasafe.com/electrical-products/recognized-certification-marks/>

To meet the requirements of the OESC, Rules 2-022 and 2-024, equipment shall be approved to a recognized Canadian standard.

Photo B1 displays the European Conformity (CE) mark which is a manufacturer’s self-declaration mark that **is not recognized in Canada**:

Photo B1 – CE marking is not recognized in Canada



2) Approval of customer owned metering equipment

This Bulletin is intended to provide direction for acceptance of customer owned metering to be used to monitor consumption of electricity beyond the revenue metering owned by the Local Distribution Company (LDC).

Question:

Can plug-in, in-line meters, which have been approved by Measurements Canada and marked, be accepted in Ontario after the service switch?

Answer:

Yes, notwithstanding Rule 2-024, meters approved by Measurement Canada are accepted. Typically, the approval number is identified as "AE-xxxx". See an example in photo B2.

Photo B2 – Socket sub meter



3) Approval of meter-mounted transfer switch devices

Background:

There are multiple manufacturers of meter-mounted transfer switches, leading to questions about approval options for meter-mounted transfer switches. In addition to the traditional, plug in-generator inlet, some devices only accept the generator hardwired to the device. See examples in photos B3 and B4.

Photo B3 - Meter-mounted transfer switch



Photo B4 - Meter-mounted transfer switch plug-in generator



Direction:

Meter-mounted transfer switches are required to be approved. Acceptable approval options are:

- Field Evaluation to SPE 1000 by a recognized Field Evaluation agency (Inspection Body).
- Certification to Standard ANSI/CAN/UL1008M “Transfer Switch Equipment.”

Note:

Meter-mounted transfer devices installed by a licensed electrical contractor (LEC) do not require a “Notification” (*) or “Connection Authorization” (**) as per Rules 2-005 f) and 2-013. However, a **“Notification” is required to hardwire a generator to a transfer switch** since it is considered an electrical installation.

(*): Since the installation requires connection of the transfer device neutral to the neutral in the meter-mounting device (meter base), these devices shall not be installed where a neutral is not present in the meter-mounting device such as a TEE Service.

(**): Unless required by LDC, connection authorization is not required.