
January 14, 2015



Product Safety Alert

The Electrical Safety Authority Warns of Unapproved Generators Sold by Aurora Generators LLC

The Electrical Safety Authority (ESA) is notifying the public about unapproved generators sold in Ontario by Aurora Generators LLC.

These products are unapproved, have not been tested for compliance with any Canadian Safety Standards and do not bear any recognized Canadian certification marks.

Distributor: Aurora Generators LLC 1619 Coastal Highway Lewes, Delaware 19958 USA Tel. (954) 251-0199, (877) 510-6807 www.EmergencyPower.com and www.AuroraGenerators.com

Manufacturer: unknown

Product: AGI50P, 50 KVA emergency standby diesel generator.

Direction: End users should immediately stop using unapproved generators and ask a licensed electrical contractor to disconnect them from circuits.

Recognized certification marks: for the list of recognized marks please visit <http://www.esasafe.com/approvedmarks> or contact ESA.