

August 18, 2015



Product Safety Alert

Cordelia Lighting Has Announced a Voluntary Corrective Action Program for its Dual Light Emergency Fixture due to Misapplication of Required Marking Labels

The Electrical Safety Authority is notifying the public that Cordelia Lighting has announced a voluntary corrective action program for the following consumer product.

Name of Product: Dual Light Emergency Fixture/ Model HB9013P Units: 4,750 units sold in Ontario; 10,755 units sold in Canada. Manufacturer: Cordelia Lighting

Hazard: A limited number of Commercial Electric Dual Light Emergency Fixtures, Model HB9013P (SKU# 656612) may have been incorrectly labeled. Certain marking labels need to be visible after installation per requirements of Canadian safety standards. The applicable marking labels were placed in locations that are not visible after installation.

Incidents/Injuries: None reported

Description/Models: Commercial Electric (HB9013P)

Sold by: Home Depot Canada

When was distributed: February 2010 – August 2015

Manufactured in: China

Remedy: Consumers should contact Cordelia Lighting to arrange for replacement labels and proper relabeling instructions to be provided.

Consumer Contact: To contact Cordelia Lighting, customers may call 1-800-345-0542 between 8:00 AM and 5:00 PM PST, send an e-mail to info@cordelia.com, or send a fax to 310-886-3497. Remarks: The HB9013P is certified to Canadian Standards by Intertek Testing Services. For more information about Intertek Testing Services product certification process please visit Intertek Testing Services Web site at: www.intertek.com.