

26 February 2026

Toronto, ON – The Electrical Safety Authority is notifying the public that Manufacture Leviton du Canada S.R.I. / Leviton Manufacturing of Canada ULC has announced a voluntary recall of the following electrical products sold in Ontario. Users should immediately have an electrician check the installation as per the remedy below. Stop using recalled products immediately until installation is confirmed and products are approved by an accredited certification agency.

Name of Product: Single/Dual Mount Charging Station Pedestal (EPED1 and EPED2)

Units: 51 in Ontario

Manufacturer/Importer: Manufacture Leviton du Canada S.R.I. / Leviton Manufacturing of Canada ULC

Identifying the products: The affected products will contain one of the following 2 date codes: 2J32V or 2K43V. The date code is located on the lower left-hand corner of the label, as depicted in the last photo below.

Hazard: The subject products are not approved by Canadian Standards Association or any other certified testing laboratory. The Canadian Electrical Code (“CEC”) requires installers to ground the product during installation. The product does not contain a ground lug leaving it to the installer to properly ground it, as per the CEC. If the product is not grounded, a potential hazard may exist.

Incidents/Injuries: None reported.

Description/Models: EPED1 and EPED2

Sold by: Electrical Wholesalers

When was distributed: 01-2023 to 05-2024

Manufactured in: China

Remedy: Product evaluation and approval by an accredited agency will be arranged by Manufacture Leviton du Canada S.R.I. / Leviton Manufacturing of Canada ULC at no cost to end users. Manufacture Leviton du Canada S.R.I. / Leviton Manufacturing of Canada ULC will work with a licensed electrical contractor to modify the product and, if not grounded, to provide a CEC compliant means to ground the product.

Consumer Contact: 1-800-405-5320

John.Papoutsakis@leviton.com

Remarks: The recalled units are not certified to Canadian Standards by a Certification Agency.

Picture of the Recalled Product




26 February 2026

Label Specs for the Pedestals:



Location (Green Box) on where the label is on the Pedestals :



26 February 2026

How the label actually looks like on the Pedestals

