



<b>9:00 am</b>	<p><b>Membership Introductions &amp; Housekeeping Items</b></p> <p><b>In Attendance: Vladimir Gagachev, Rob Smith, Carita Edwards, Farrah Bourre, Tony Poirer, Peter Olders, Barry Buchanan, Eric Randsalu, Malcolm Brown, Dave Sinclair, Tim Pope, Martin Lem, Ted Olechna, Tatjana Dinic</b></p> <p><b>Teleconference: Mary Beth Fazzari, George Chelvanayagam</b></p> <p><b>Guests: Jason Huyn, Aisling O’Doherty</b></p> <p>New members: Tim Pope, Martin Lem, Kathryn Farmer</p>
<b>9:15 am</b>	<p><b>Review Potential Areas of Focus for the 2018 OESC</b></p> <p>Presented by Ted Olechna</p> <p>See presentation</p> <p><b>Questions</b></p>
<b>10:00 am</b>	<p><b>CSA Part 1 Highlights</b></p> <p>Presented by Ted Olechna</p> <ul style="list-style-type: none"> <li>(1) Definition of Cable, definition of conductor, -bare, covered, insulated. Approved removed for individual rules</li> <li>(2) 6-212</li> <li>(3) Section 8 and 86</li> <li>(4) 10-000 Scope</li> <li>(5) 12-2300</li> <li>(6) Section 18</li> <li>(7) Section 12 and the Roofing Industry</li> <li>(8) Arc Lamps</li> <li>(9) POE Wiring</li> <li>(10)Marinas, Wharfs and Docks</li> <li>(11)Section 62</li> </ul>
<b>10:15 am</b>	<p><b>Break</b></p>
<b>10:30 am</b>	<p><b>AFCI Nuisance Tripping</b></p> <p>Presented by Ted Olechna</p> <p>See presentation</p>
<b>10:45 am</b>	<p><b>Animal Containment Barns</b></p> <p>Presented by Malcolm Brown</p> <p>See presentation</p>
<b>11:00 am</b>	<p><b>Code Proposal Submitted and Considered</b></p>



**Electrical  
Safety  
Authority**

**Ontario Provincial Code Council  
Meeting Minutes**

*September 12<sup>th</sup>, 2017 9:00 am - 1:00 pm*  
Summerville Room, Four Points by Sheraton,  
2501 Argenta Rd, Mississauga

<b>11:45 am</b>	Presented by Ted Olechna
	See presentation
<b>11:50 am</b>	<b>Impact Assessment</b> Presented by Tatjana Dinic
	See presentation
<b>12:00 pm</b>	<b>EV Chargers and Ontario Building Codes</b> Presented by Tatjana Dinic
	<ul style="list-style-type: none"> <li>-Apartment buildings have not been confirmed.</li> <li>-“In a building” means within a building. Beside is not covered is not covered by the regulation.</li> <li>-This change is going to affect utilities in regards to townhouses as each will be required to have a 200A service. They will have to upgrade their lines and transformers.</li> <li>- This should not have an impact on ESA as the change is in the OBC, something we do not control over.</li> <li>- OBC uses the word conduit when they mean the word raceway, they use the word panelboard when they mean service. Difficulties with proper language.</li> </ul>
	<b>Lunch</b>
	<b>Next meeting: December 12<sup>th</sup></b>