

Pad-mount Equipment Protection & Construction Projects

Introduction

This bulletin provides information for Electrical Distributors to assist in maintaining damage free, pad-mounted equipment that exist near construction projects.

ESA Recommends

ESA recommends LDCs review the practice of installing temporary barriers around pad-mounted equipment that exist near construction projects. Electrical Distributors that have employed this practice and ESA believes it is a good practice to protect equipment from creating safety concerns and damage. The bottom picture shows a plywood barrier that is removed, only with permission of the Electrical Distributor.

