

Proposal Number: 2018-OA-006

**Rule 2-010**

**Description of Change: Editorial change to clarify when Plan Review is not required**  
**Proposed by: Electrical Safety Authority**

**Background:**

Subrule (1) states all cases where a plan review submittal is required. Exemptions to these requirements are stated in multiple Subrules (2)(3) and (4).

**Rationale:**

This proposal is editorial only and is meant to group all exemptions to plan review requirements in a single subrule. The current wording is repetitive by stating “Plans need not be submitted” in three separate subrules.

**Proposed Change:**

***Amend 2-010 and renumber subrules***

**2-010 Plans and specifications (see Appendix B)**

(...)

(2) Plans need not be submitted for ~~maintenance/repair work.~~

(a) maintenance/repair work

~~(3)(b) Plans need not be submitted for~~ temporary installations, and work within the scope of Section 76, for equipment operating at not more than 750 V phase-to-phase or not more than 1000 A; ~~or~~

~~(4)(c) Plans need not be submitted for~~ the replacement of electrical equipment, provided that

~~(a)(i)~~ equipment electrical characteristics are the same as the existing equipment characteristics; and

~~(b)(ii)~~ the existing installation meets the requirements of this Code.

(...)