

Proposal Number: 2018-OA-011

Rule 24-104(2)

Description of Change: Delete current Ontario Amendment to Rule 24-104(2)

Submitted by: Electrical Safety Authority

Background:

Deleting this requirement as the CE Code 2018 has adopted the requirements in Ontario Amendment (OESC 2015) Rule 24-104(2).

Rationale:

The new rule wording in the CE Code 2018 has replaced “or” with “and” as was proposed by Ontario Amendment in CE Code 2015.

Proposed Change:

Delete Ontario Amendment to Rule 24-104(2)

~~Amend the first paragraph of CE Code Rule 24-104(2) as follows:~~

~~Δ (2) All receptacles and other permanently connected equipment shall be bonded to ground by copper equipment bonding conductors, sized in accordance with Table 16A or 16B as applicable, but in no case smaller than No. 12 AWG, installed in accordance with Rule 10-808 and run with the circuit conductors in accordance with the following:~~