

Proposal Number: 2018-OA-014

**Rule 30-200(1)**

**Description of Change: Delete existing Ontario Amendment to CE Code Rule 30-200(1)**

**Submitted by: Electrical Safety Authority**

**Background & Rationale:**

Rule 30-200 in the CE Code had been amended to adopt the wording from OESC Rule 30-200 and the amendment to the rule is no longer required. The Appendix B note, which was added as part of this Ontario Amendment in OESC 26<sup>th</sup> Edition, will remain to explain the intent and give guidance to the application of the Rule.

**Proposed Change:**

*Delete Amendment to Rule 30-200(1)*

**30-200 Near or over combustible material (see Appendix B)**

~~Delete CE Code Rule 30-200(1) and replace with the following:~~

~~(1) Luminaires installed near or over combustible material or where combustible material is liable to be stored shall be equipped with shades or guards to limit the temperature to which the combustible material may be subjected to a maximum of 90 °C.~~