

Court Date:	March 30, 2016
Defendant:	1137749 Ontario Limited operating as Pro-Teck Electric (Niagara Falls, Ontario)
City	Niagara Falls, Ontario
Site:	178 John Street, West, Niagara-on-the-Lake, Ontario
Charge(s):	(1) <i>Fail to Apply for Inspection</i> , Rule 2-004(1) Ontario Electrical Safety Code
	(2) <i>Unsafe Electrical Conditions</i> , Rule 2-200 Ontario Electrical Code
	(3) <i>Fail to Procure Authorization Before Used</i> , Rule 2-004(3) Ontario Electrical Safety Code
Offence Date:	Between March 1 st and April 30th, 2014
Date Charge Laid:	August 12, 2014
Counsel/agent:	Prosecution-Ian JOHNSTONE & Phil WRIGHT Defense-Brent HARASYM
Plea:	Guilty-on April 29 th , 2105
Disposition:	(1) \$60,000 Fine + \$15,000 victim surcharge
	(2) \$250,000 Fine+ \$62,500 victim surcharge
	(3) \$120,000 Fine + \$30,000 victim surcharge
Remarks:	Licensed Electrical Contractor installed an in-floor heating system without filing an application for inspection. An elderly gentleman

	<p>fell on the floor in the bathroom, where the in-floor heating system was installed, and suffered second and third degree burns from the over-heated floor and succumbed to his injuries. The floor system's heat sensor had not been installed and the heating system was wired to an incorrect voltage.</p>
--	---

**There is another Licensed Electrical Contractor with a similar name out of Richmond Hill which has no relation to this company*