

Court Date:	January 13, 2020
Defendant:	Andrew Charles McKibbon, Peterborough
Court City:	Peterborough
Site:	1121 Armour Road, Unit 13, Peterborough
Charge(s):	(1) <i>Fail to Apply for Inspection</i> , Rule 2-004(1) Ontario Electrical Safety Code
	(2) <i>Insufficient Guarding</i> , Rule 2-200 Ontario Electrical Safety Code
	(3) <i>No Electrical Contractor's Licence</i> , Part VIII of the Electricity Act & O. Reg 570/05
Offence Date:	Between January 1, 2018 and February 12, 2018.
Date Charge Laid:	August 2, 2019
Plea:	Guilty
Disposition:	(1) Suspended Sentence
	(2) \$5,000 fine plus \$1,250 victim surcharge
	(3) \$5,000 fine plus \$1,250 victim surcharge
Remarks:	Installation of a generator which resulted in life and/or property defects. An LEC was hired to correct the defects