

Enforcement Convictions

Court Date:	May 15, 2017
Defendant:	JF Industrial Services Inc., Ontario Corp Number 186910, Oldcastle
Court City:	Windsor
Site:	Bello Metal Products, 5515 Maplewood Dr, Windsor
Charge(s):	<p>(1) <i>Fail to Disconnect Power Before Altering Live Electrical Equipment</i> - Rule 2-304 (1) Electrical Safety Code, pursuant to the Electricity Act section 113 (13).</p> <p>(2) <i>No Electrical Contractor's Licence</i>, Part VIII of the Electricity Act & O. Reg 570/05</p>
Offence Date:	September 7, 2016
Date Charge Laid:	December 6, 2016
Plea:	Guilty
Disposition:	<p>(1) \$5,000 fine plus \$1,250 victim surcharge</p> <p>(2) Suspended Sentence</p>
Remarks:	Employee of unlicensed contractor was removing a feeder when an arc flash occurred. A licensed electrical contractor was hired to make repairs after the incident.