

Court Date:	January 9, 2017
Defendant:	Joseph Rooney, operating as CliCom Environmental Systems, Maidstone
City:	Windsor
Site:	Park View Tower Apartments, 76 Tecumseh Rd E, Windsor
Charge(s):	(1) <i>No Electrical Contractor's Licence</i> , Part VIII of the Electricity Act & O. Reg 570/05
	(2) <i>Fail to Apply for Inspection</i> , Rule 2-004(1) Ontario Electrical Safety Code
Offence Date:	Between October 19, 2015 and December 27, 2015
Date Charge Laid:	March 9, 2016
Plea:	Not Guilty
Disposition:	(1) \$2,000 Fine plus \$500 victim surcharge
	(2) Dismissed
Remarks:	<p>Unlicensed contractor was hired to add gas water heaters. While in the process of removing the heater, the panel board was damaged causing an electrical fire in the panel.</p> <p>A Licensed Electrical Contractor was hired to replace the panel board.</p>